

# 2015 Water Quality Report for Village of Almont

This report covers the drinking water quality for the Village of Almont, for the calendar year 2015. This information is a snapshot of the quality of the water that we provided to you in 2015. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.

Your source water comes from the Lake Huron Water Treatment Plant located five miles north of the City of Port Huron. The water arrives at the plant via a deep tunnel with the intake offshore under 45 feet of water. The water is pumped from the water treatment plant to the Village of Almont. Your source water comes from the lower Lake Huron watershed; the watershed includes numerous short, seasonal streams that drain to Lake Huron. The Michigan Department of Environmental Quality in partnership with U.S. Geological Survey, The Great Lakes Water Authority, and the Michigan Public Health Institute performed a source water assessment in 2004 to determine the susceptibility of potential contaminant. The susceptibility rating is on a seven-tiered scale from very low to very high based primarily on geologic sensitivity, water chemistry, and contaminant sources. The Lake Huron water treatment plant has historically provided satisfactory treatment of this source water to meet drinking water standards. If you would like to know more about this report please contact your local water department at (810)798-8528. The Village of Almont also has a groundwater well located at 121 West St. Clair Street. We use this well only in emergencies, for example, if the Lake Huron plant or the pipeline is out of service. The State will be performing an assessment of our source water. We will inform you on how to get a copy of the assessment report when it becomes available.

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline (800-426-4791)**.
- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).
- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.
- Contaminants that may be present in source water include:
  - Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
  - Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
  - Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
  - Radioactive contaminants**, which are naturally occurring or be the result of oil and gas production and mining activities.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

### Water Quality Data

The table below lists some drinking water contaminants that we detected in our West St. Clair Street well in the past. Attached is the water quality data from the Lake Huron Water Treatment Plant. The Great Lakes Water Authority Department provided this information. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2015. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

**Terms and abbreviations used below:**

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **N/A:** Not applicable **ND:** not detectable at testing limit **ppb:** parts per billion or micrograms per liter **ppm:** parts per million or milligrams per liter **pCi/l:** picocuries per liter (a measure of radiation).
- **Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- Stand-by Well #3 (St. Clair Street)

Regulated Contaminant	MCL	MCLG	Our Water	Sample Date (Year)	Violation Yes / No	Typical Source of Contaminant
Arsenic (mg/l)	.010	N/A	.002	6/25/2014	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Volatile Organic Compounds (mg/l)	.02-.10	N/A	ND	7/7/2015	No	Include Components of petroleum based products and industrial solvents and chemicals
Pesticides	.01-.05	N/A	ND	7/7/2015	No	A chemical that is used to kill animals or insects that damage plants or crops
Herbicides	.01-.07	N/A	ND	7/7/2015	No	A chemical used to destroy plants or plant growth
Carbamates	.02-.04	N/A	ND	7/7/2015	No	A salt of Carbamic acid one that is a synthetic organic insecticide
Cyanide (mg/l)	.02	N/A	ND	7/7/2015	No	Used to make compounds for nylon and other synthetic fibers and resin as well as being found in Herbicides
Nitrate /Nitrite (mg/l)	Nitrate 10 Nitrite 1	N/A	ND	7/7/2015	No	Nitrate is a form of nitrogen combined in with oxygen /Nitrite can get into a well when it was improperly installed
Sulfate (mg/l)	Not regulated		39	6/24/2014	no	Erosion of natural deposits

\* Unregulated contaminant monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline at 800-426-4791.

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill, and if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.

Is our water system meeting other rules that govern our operations? The State and EPA require us to test our water on a regular basis to ensure its safety.

We met all the monitoring and reporting requirements for 2015.

We are committed to providing you safe, reliable, and healthy water. We are pleased to provide you with this information to keep you fully informed about your water. We will be updating this report annually, and will also keep you informed of any problems that may occur throughout the year, as they happen.

We invite public participation in decisions that affect drinking water quality. You are invited to attend the Village Council meetings held the first and third Tuesday of each month at 7:30 p.m. at the Almont Municipal Building. For more information about your water, or the contents of this report, contact Bryan Treat at (810) 798-8655. For more information about safe drinking water, visit the U.S. Environmental Protection Agency at [www.epa.gov/safewater/](http://www.epa.gov/safewater/).

### Key to Detected Contaminants Table

Symbol	Abbreviation for	Definition/Explanation
<b>MCLG</b>	Maximum Contaminant Level Goal	The level of contaminant in drinking water below which there is no known or expected risk to health.
<b>MCL</b>	Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
<b>MRDLG</b>	Maximum Residual Disinfectant level goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRLDG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.
<b>MRDL</b>	Maximum Residual Disinfectant Level	The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
<b>ppb</b>	Parts per billion (one in one billion)	The ppb is equivalent to micrograms per liter. A microgram = 1/1000 milligram.
<b>ppm</b>	Parts per million (one in one million)	The ppm is equivalent to milligrams per liter. A milligram = 1/1000 gram.
<b>NTU</b>	Nephelometric Turbidity Units	Measures the cloudiness of water.
<b>ND</b>	Not Detected	
<b>TT</b>	Treatment Technique	A required process intended to reduce the level of a contaminant in drinking water.
<b>AL</b>	Action Level	The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.
<b>HAA5</b>	Haloacetic acids	HAA5 is the total of bromoacetic, chloroacetic, dibromoacetic, dichoroacetic, and trichloroacetic acids. Compliance is based on the total .
<b>TTHM</b>	Total Trihalomethanes	Total Trihalomethanes is the sum of chloroform, bromodichloromethane, dibromoochloromethane and bromoform. Compliance is based on total.
<b>pCi/l</b>	picocuries per liter	a measure of radioactivity
<b>n/a</b>	not applicable	
<b>&gt;</b>	Greater than	

**Lake Huron Water Treatment Plant  
2015 Regulated Detected Contaminants Tables**

Regulated Contaminant	Test Date	Unit	Health Goal <b>MCLG</b>	Allowed Level <b>MCL</b>	Highest Level Detected	Range of Detection	Violation yes/no	Major Sources in Drinking Water
<b>Inorganic Chemicals – Monitoring at the Plant Finished Water Tap</b>								
Fluoride	5/13/14	ppm	4	4	0.59	n/a	no	Erosion of natural deposits; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	5/13/14	ppm	10	10	0.31	n/a	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
<b>Disinfection By-Products – Monitoring in Distribution System Stage 2 Disinfection By-Products</b>								
Regulated Contaminant	Test Date	Unit	Health Goal <b>MCLG</b>	Allowed Level <b>MCL</b>	Highest LRAA	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Total Trihalomethanes (TTHM)	2015	ppb	n/a	80	0.0254	.0074 - .0262	No	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	2015	ppb	n/a	60	0.010	.002 - .011	No	By-product of drinking water disinfection
<b>Disinfectant Residuals Monitoring in DWSD Distribution System</b>								
Regulated Contaminant	Test Date	Unit	Health Goal <b>MRDGL</b>	Allowed Level <b>MRDL</b>	Highest RAA	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Total Chlorine Residual	Jan-Dec 2014	ppm	4	4	0.82	0.64-0.94	no	Water additive used to control microbes
Regulated Contaminant	Treatment Technique							Typical Source of Contaminant
Total Organic Carbon (ppm)	The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC was measured each month and because the level was low, there is no requirement for TOC removal.							Erosion of natural deposits

<b>2013 Turbidity – Monitored every 4 hours at Plant Finished Water Tap</b>			
Highest Single Measurement Cannot exceed 1 NTU	Lowest Monthly % of Samples Meeting Turbidity Limit of 0.3 NTU (minimum 95%)	Violation yes/no	Major Sources in Drinking Water
0.19 NTU	100%	no	Soil Runoff
Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.			

<b>2014 Microbiological Contaminants – Monthly Monitoring in Distribution System</b>					
Regulated Contaminant	MCLG	MCL	Highest Number Detected	Violation yes/no	Major Sources in Drinking Water
Total Coliform Bacteria	0	Presence of Coliform bacteria > 5% of monthly samples	0	no	Naturally present in the environment.
<i>E.coli</i> Bacteria	0	A routine sample and a repeat sample are total coliform positive, and one is also fecal or <i>E. coli</i> positive.	0	no	Human waste and animal fecal waste.

<b>2014 Lead and Copper Monitoring at Customers' Tap</b>								
Regulated Contaminant	Test Date	Unit	Health Goal <b>MCLG</b>	Action Level <b>AL</b>	90 <sup>th</sup> Percentile Value*	Number of Samples Over AL	Violation yes/no	Major Sources in Drinking Water
Lead	2014	ppb	0	15	0 ppb	5	no	Corrosion of household plumbing system; Erosion of natural deposits.
Copper	2014	ppm	1.3	1.3	100 ppb	5	no	Corrosion of household plumbing system; Erosion of natural deposits; Leaching from wood preservatives.

\*The 90th percentile value means 90 percent of the homes tested have lead and copper levels below the given 90th percentile value. If the 90th percentile value is above the AL additional requirements must be met.

<b>2014 Radionuclides</b>							
<b>Regulated Contaminant</b>	<b>Test Date</b>	<b>Unit</b>	<b>Health Goal MCLG</b>	<b>Allowed Level MCL</b>	<b>Level Detected</b>	<b>Violation yes/no</b>	<b>Major Sources in Drinking Water</b>
Combined Radium Radium 226 & 228	5/13/14	pCi/L	0	5	0.86 + or - 0.55	no	Erosion of natural deposits

**2015 Special Monitoring**

<b>Contaminant</b>	<b>MCLG</b>	<b>MCL</b>	<b>Level Detected</b>	<b>Source of Contamination</b>
Sodium (ppm)	n/a	n/a	4.78	Erosion of natural deposits

Collection, sampling result information and table provided by Great Lakes Water Authority Water Quality Division, ML Semegen